

This document has been translated for informative purpose only.  
Original version in German. In any case of doubt the German version is valid.

## EC-CERTIFICATE OF CONFORMITY

**0672 - CPD - 0082**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction products

### Overhead Door Closers

**„GEZE TS 3000“, „GEZE TS 3000 V“, „GEZE TS 3000 V BC“,  
„GEZE TS 3000 EN 3-4“, „GEZE TS 3000 EC“ and  
„GEZE TS 3000 EC BC“,**  
with the classification enclosed in this certificate

placed on the market by

**GEZE GmbH  
Reinhold-Vöster-Str. 21-29  
D-71229 Leonberg**

and produced in the factory

**GEZE GmbH  
Reinhold-Vöster-Str. 21-29  
D-71229 Leonberg**

are submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved bodies have performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**EN 1154:1996 + A1:2002**

were applied and that the products fulfil all the prescribed requirements.

This certificate was first issued on March 21<sup>st</sup>, 2005, , replaced by the version of May, 26<sup>th</sup>, 2008 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Stuttgart, May 26<sup>th</sup>, 2008


Materials Testing Institute – University of Stuttgart  
Section Fire Resistance of Construction Components  
Certification Body

*Wies*

(Dr. rer. nat. S. Wies)  
Deputy Head of the Certification Body







## Enclosure to the EC–Certificate of Conformity

### 0672 – CPD – 0082

#### Classification of the door closers

GEZE TS 3000	EN 1154	4	8	3	1	1	4
GEZE TS 3000 V GEZE TS 3000 V BC	EN 1154	4	8	4 1	1	1	4
GEZE TS 3000 EN 3-4	EN 1154	4	8	4 3	1	1	3
GEZE TS 3000 EC GEZE TS 3000 EC BC	EN 1154	4	8	3 2	1	1	4

**Note:** The manufacturer has to point out in the assembly and adjustment documents of the door closer, that the door closer should be at least on size 3 for use on fire/smoke door assemblies.

Stuttgart, May, 26<sup>th</sup>, 2008

Materials Testing Institute – University of Stuttgart  
Section Fire Resistance of Construction Components  
Certification Body

(Dr. rer. nat. S. Wies)  
Deputy Head of the Certification Body

